



Education, Careers & Lifelong Community for People with Special Needs

June 6, 2022

Community of ECLC of New Jersey
HoHoKus Campus
302 Franklin Turnpike
Ho-Ho-Kus, NJ 07423

Re: Water Quality Testing

Dear Members of the Community of ECLC of New Jersey:

ECLC of New Jersey is committed to protecting student, teacher, and staff health. To protect our community and to comply with the Department of Education regulations, our HoHoKus school tested our schools' drinking water for lead.

Testing indicated levels in our school within the limits deemed safe. However, we also tested water sources in the basement of the St. Luke's parish center, since we occasionally utilize the basement gym for our activities. Two sinks – **but no water fountains used for drinking purposes** – in this basement area indicated levels above the maximum permitted.

In accordance with the Department of Education regulations, ECLC's HoHoKus Campus has implemented remedial measures for the four sinks with a result greater than the action level of 15 µg/l (parts per billion [ppb]). Because these water sources must remain on for non-drinking purposes, we have identified these water outlets with signs reminding students and staff that they should not be used for drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" have been posted.

Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings accessible to students of our HoHoKus campus. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the forty (40) samples taken, all but the four (4) sinks discussed above have tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

Peter Petrou
Executive Director
ppetrou@eclcofnj.org

Administrative Office
100 Passaic Avenue
Suite I
Chatham, NJ 07928
973-635-1705
Fax: 973-635-0548

Chatham Campus
21 Lum Avenue
Chatham, NJ 07928

Ho-Ho-Kus Campus
302 N. Franklin Turnpike
Ho-Ho-Kus, NJ 07423

CPS, Inc.
54 Fairmount Avenue
Chatham, NJ 07928

PRIDE Centers
100 Passaic Avenue
Chatham, NJ 07928

403 Sette Drive
Paramus, NJ 07652

Board of Trustees
Christine Batt
Anita Bluestone, LCSW
Gayle L. Czeizler
Paul A. DeLeone
Stephen N. Dratch, Esq.
Jane M. Fischer, MA
Richard Gatward
Douglas J. Hamilton
Kathryn V. Hatfield, Esq.
Helene Jaffe, LSW
Carol Lampf
Bruce Litinger
Michael R. Luke, Esq.
Joseph J. Murphy, DC
Kevin O'Malley
Vivian Schwartz, MPA
Barbie Vartanian

Trustees Emeritus
Jonathan D. Clemente, Esq.

Founding Board Member
Bebe Antell, MA

We do not discriminate on the basis of race, national origin, gender or other protected classification.

A New Jersey Non-Profit Corporation
Lifelong Programs for Students and Adults with Developmental Disabilities

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action [School District Name] has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Left Sink in Boys Bathroom of Church Gym	46.4	Posted signage “DO NOT DRINK- SAFE FOR HANDWASHING ONLY”
Right Sink in Boys Bathroom of Church Gym	35.7	Posted signage “DO NOT DRINK- SAFE FOR HANDWASHING ONLY”

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person’s total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person’s total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.eclcofnj.org. For more information about water quality in our schools, contact Randy Peterson at the HoHoKus School, [Phone Number].

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Very truly yours,



Peter Petrou
Executive Director

PP:noe



LEAD IN POTABLE WATER SCREENING REPORT

INVESTIGATION FOR: Valentina Baldessarre
Archdiocese of Newark
171 Clifton Avenue
P.O. Box 9500
Newark, NJ 07104

SITE INVESTIGATED: St. Luke/ECLC
302 N. Franklin Turnpike
Ho-Ho-Kus, NJ 07423

ASSESSMENT BY: Ross Hernandez
Omega Environmental Services, Inc.
280 Huyler Street
South Hackensack, NJ 07606

INVESTIGATION
CONDUCTED: 8/3/2021

DATE OF REPORT: 9/17/2021

(Omega Project # 21-26004)

TABLE OF CONTENTS

EXECUTIVE SUMMARY/PROJECT OVERVIEW

1. RESULTS TABLE
2. SAMPLING METHODOLOGY
3. DISCUSSION OF RESULTS
4. RECOMMENDATIONS

Appendices:

A. Laboratory Analytical Reports

EXECUTIVE SUMMARY:

The Archdiocese of Newark requested representative lead in water testing of potable water outlets at St. Luke/ECLC located at 302 N. Franklin Turnpike, Ho-Ho-Kus, New Jersey 07423.

Previous Testing

On June 16, 2016, Omega performed screen testing of all potable outlets. First draw and flush samples (30 second) were collected at forty (40) water fountains and sinks.

Reportedly the outlets were not flushed or used on the day of testing.

One (1) first draw sample and the associated flush sample result were above Lead and Copper Rule action level of 15 ppb.

See report dated July 15, 2016.

Follow-up Current Testing (8/3/2021)

In order to assess the building water outlets, follow-up testing of representative potable outlets was performed on August 3, 2021.

Reportedly all outlets were flushed the day prior to sampling.

First draw and flush samples (30 second) were collected at 40 water fountains and sinks.

Results of most (38-out-of-40 total samples) first draw samples analyzed were below the Lead action level of 15 ppb. Two (2) first draw sample results were above 15 ppb. Both of the associated flush samples were above 15 ppb.

See Section 3 Discussion of Results

Applicable Corrective Action

The positive outlets should not be used by students/staff but should continue to be flushed daily or weekly pending re-test.

Water Management/Plumbing Plan

A water management/plumbing plan has been created for St. Luke/ECLC.

1 RESULTS TABLE:

Sample #	Location	1 st draw (FD) or flush (FL)	Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
01 FD	Room 101 Sink	FD	4.50	15
01 FL	Room 101 Sink	FL	NA	15
02 FD	Water Fountain Bubbler at 1 st Floor Boy's Bathroom	FD	1.30	15
02 FL	Water Fountain Bubbler at 1 st Floor Boy's Bathroom	FL	NA	15
03 FD	1 st Floor Boy's Bathroom Left Sink	FD	1.30	15
03 FL	1 st Floor Boy's Bathroom Left Sink	FL	NA	15
04 FD	1 st Floor Boy's Bathroom Middle Sink	FD	1.16	15
04 FL	1 st Floor Boy's Bathroom Middle Sink	FL	NA	15
05 FD	1 st Floor Boy's Bathroom Right Sink	FD	1.15	15
05 FL	1 st Floor Boy's Bathroom Right Sink	FL	NA	15
06 FD	Bottleless Water Fill by Main Entrance	FD	ND	15
06 FL	Bottleless Water Fill by Main Entrance	FL	NA	15
07 FD	Main Office Bathroom Sink	FD	ND	15
07 FL	Main Office Bathroom Sink	FL	NA	15
08 FD	Principal's Office Bathroom Sink	FD	1.12	15
08 FL	Principal's Office Bathroom Sink	FL	NA	15
09 FD	Water Fountain Bubbler Next to Room 103	FD	2.35	15
09 FL	Water Fountain Bubbler Next to Room 103	FL	NA	15
10 FD	Room 103 Sink	FD	1.45	15
10 FL	Room 103 Sink	FL	NA	15
11 FD	Water Fountain Bubbler Next to Ladies Room	FD	6.00	15
11 FL	Water Fountain Bubbler Next to Ladies Room	FL	NA	15
12 FD	1 st Floor Ladies Room Left Sink	FD	1.08	15
12 FL	1 st Floor Ladies Room Left Sink	FL	NA	15
13 FD	1 st Floor Ladies Room Middle Sink	FD	1.54	15
13 FL	1 st Floor Ladies Room Middle Sink	FL	NA	15
14 FD	1 st Floor Ladies Room Right Sink	FD	2.36	15
14 FL	1 st Floor Ladies Room Right Sink	FL	NA	15
15 FD	1 st Floor Teacher's Lounge Sink	FD	2.80	15
15 FL	1 st Floor Teacher's Lounge Sink	FL	NA	15
16 FD	1 st Floor Teacher's Lounge Bottleless Water Fill	FD	ND	15
16 FL	1 st Floor Teacher's Lounge Bottleless Water Fill	FL	NA	15
17 FD	Nurse's Bathroom Sink	FD	1.02	15
17 FL	Nurse's Bathroom Sink	FL	NA	15
18 FD	Bottleless Water Fill Next to Room 207	FD	ND	15
18 FL	Bottleless Water Fill Next to Room 207	FL	NA	15
19 FD	Water Fountain Bubbler Next to Room 207	FD	1.78	15
19 FL	Water Fountain Bubbler Next to Room 207	FL	NA	15
20 FD	Room 207 Sink	FD	1.01	15
20 FL	Room 207 Sink	FL	NA	15
21 FD	Room 207 Bathroom Sink	FD	2.59	15
21 FL	Room 207 Bathroom Sink	FL	NA	15
22 FD	Men's Bathroom Sink Across from Room 208	FD	ND	15
22 FL	Men's Bathroom Sink Across from Room 208	FL	NA	15
23 FD	2 nd Floor Boys Bathroom Next to Room 201 Left Sink	FD	2.94	15
23 FL	2 nd Floor Boys Bathroom Next to Room 201 Left Sink	FL	NA	15
24 FD	2 nd Floor Boys Bathroom Next to Room 201 Middle Sink	FD	2.00	15
24 FL	2 nd Floor Boys Bathroom Next to Room 201 Middle Sink	FL	NA	15

25 FD	2 nd Floor Boy's Bathroom Next to Room 201 Right Sink	FD	1.78	15
25 FL	2 nd Floor Boy's Bathroom Next to Room 201 Right Sink	FL	NA	15
26 FD	Water Fountain Bubbler Next to Room 201	FD	7.82	15
26 FL	Water Fountain Bubbler Next to Room 201	FL	NA	15
27 FD	Bottleless Water Fill Next to Room 211	FD	ND	15
27 FL	Bottleless Water Fill Next to Room 211	FL	NA	15
28 FD	Water Fountain Bubbler Next to Room 203	FD	4.33	15
28 FL	Water Fountain Bubbler Next to Room 203	FL	NA	15
29 FD	Room 204 Sink	FD	1.64	15
29 FL	Room 204 Sink	FL	NA	15
30 FD	Water Fountain Bubbler Next to Room 204	FD	4.28	15
30 FL	Water Fountain Bubbler Next to Room 204	FL	NA	15
31 FD	2 nd Floor Girl's Bathroom Next to Room 205 Left Sink	FD	1.13	15
31 FL	2 nd Floor Girl's Bathroom Next to Room 205 Left Sink	FL	NA	15
32 FD	2 nd Floor Girl's Bathroom Next to Room 205 Middle Sink	FD	ND	15
32 FL	2 nd Floor Girl's Bathroom Next to Room 205 Middle Sink	FL	NA	15
33 FD	2 nd Floor Girl's Bathroom Next to Room 205 Right Sink	FD	3.24	15
33 FL	2 nd Floor Girl's Bathroom Next to Room 205 Right Sink	FL	NA	15
34 FD	Bottleless Water Fill in Music/Language Arts (Room 304)	FD	ND	15
34 FL	Bottleless Water Fill in Music/Language Arts (Room 304)	FL	NA	15
35 FD	Room 304 Skils Kitchen Sink	FD	2.41	15
35 FL	Room 304 Skils Kitchen Sink	FL	NA	15
36 FD	Boy's Bathroom Left Sink in Church Gym	FD	46.4	15
36 FL	Boy's Bathroom Left Sink in Church Gym	FL	27.7	15
37 FD	Boy's Bathroom Right Sink in Church Gym	FD	35.7	15
37 FL	Boy's Bathroom Right Sink in Church Gym	FL	32.5	15
38 FD	Girl's Bathroom Left Sink in Church Gym	FD	13.1	15
38 FL	Girl's Bathroom Left Sink in Church Gym	FL	NA	15
39 FD	Girl's Bathroom Right Sink in Church Gym	FD	10.9	15
39 FL	Girl's Bathroom Right Sink in Church Gym	FL	NA	15
40 FD	Unisex Bathroom in Church Gym	FD	5.84	15
40 FL	Unisex Bathroom in Church Gym	FL	NA	15

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

ND – Indicates that the analyte was not detected at the reporting limit

NA – Not Analyzed

2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO₃) as a preservative.

Flush Samples – After collection of first draw samples the water was allowed to flow at a relatively slow rate for thirty second to flush the fixture and close piping. The flush samples are intended to test the plumbing further upstream from the fixture (behind walls).

The samples were packaged in a cooler and shipped to EMSL Analytical, Inc. in Cinnaminson, NJ for total lead in potable water analysis (method E200.8 IOC).

3 DISCUSSION OF RESULTS:

Two (2) first draw sample results were above 15 ppb. Both of the associated flush samples were above 15 ppb. This indicates the source of lead is related to the main building plumbing.

4 RECOMMENDATIONS:

Short term:

- Take any outlets with elevated results out of service.
- Conduct further evaluation, flushing, and testing of outlets with elevated results.

Contact Omega Environmental to discuss specific recommendations.

Long Term:

- **If additional testing shows similar results (first draw results above 15 ppb) consider replacing the spout of the fountains (may contain brass, adding to lead levels), installing filters (if practical), or fixture replacement.**
- Repeat full building testing on an annual basis. Generally, this should be performed in August prior to the start of the school season.
- Develop a Lead in Water Management Plan in accordance with the 2006 EPA 3Ts for Reducing Lead in Drinking Water in Schools.

A. Lead in Water Laboratory Reports



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 856-4571 Email: EnvChemistry2@emsl.com

Attn:

Lab

8/31/2021

Omega Environmental Services

280 Huyler Street

South Hackensack, NJ 07606

Phone: (201) 489-8700

Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/10/2021. The results are tabulated on the attached data pages for the following client designated project:

Arch of Newark/St. Luke ECLC / 21-26004

The reference number for these samples is EMSL Order #012109114. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114

CustomerID: OMEG50

CustomerPO: 21-26004

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description 01FD Room 101 Sink Mixing Valve		Collected: 8/3/2021 7:54:00 AM		Lab ID: 012109114-0001	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.50	1.00 µg/L	8/26/2021 VD	08/27/21 9:56 VD
Client Sample Description 02FD Water Fountain Bubbler at 1st Floor Boys Bathroom		Collected: 8/3/2021 7:58:00 AM		Lab ID: 012109114-0003	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	8/26/2021 VD	08/27/21 10:02 VD
Client Sample Description 03FD 1st Floor Boy's Bathroom Left Sink Mixing Valve		Collected: 8/3/2021 8:00:00 AM		Lab ID: 012109114-0005	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	8/26/2021 VD	08/27/21 5:04 VD
Client Sample Description 04FD 1st Floor Boy's Bathroom Middle Sink Mixing Valve		Collected: 8/3/2021 8:01:00 AM		Lab ID: 012109114-0007	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	8/26/2021 VD	08/27/21 5:07 VD
Client Sample Description 05FD 1st Floor Boy's Bathroom Right Sink Mixing Valve		Collected: 8/3/2021 8:02:00 AM		Lab ID: 012109114-0009	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 µg/L	8/26/2021 VD	08/27/21 5:09 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description 06FD Bottleless Water Fill by Main Entrance		Collected: 8/3/2021 8:05:00 AM		Lab ID: 012109114-0011	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2021 VD	08/27/21 5:12 VD
Client Sample Description 07FD Main Office Bathroom Sink		Collected: 8/3/2021 8:11:00 AM		Lab ID: 012109114-0013	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2021 VD	08/27/21 5:21 VD
Client Sample Description 08FD Principals Office Bathroom Sink		Collected: 8/3/2021 8:13:00 AM		Lab ID: 012109114-0015	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.12	1.00 µg/L	8/26/2021 VD	08/27/21 5:23 VD
Client Sample Description 09FD Water Fountain Bubbler next to Room 103		Collected: 8/3/2021 8:16:00 AM		Lab ID: 012109114-0017	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.35	1.00 µg/L	8/26/2021 VD	08/27/21 5:26 VD
Client Sample Description 10FD Room 103 Sink Mixing Valve		Collected: 8/3/2021 8:18:00 AM		Lab ID: 012109114-0019	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	8/26/2021 VD	08/27/21 5:29 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114

CustomerID: OMEG50

CustomerPO: 21-26004

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description		11FD Water Fountain Bubbler next to Ladies Room	Collected:		8/3/2021 8:21:00 AM	Lab ID:		012109114-0021
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	6.00	1.00 µg/L	8/26/2021	VD	08/27/21 4:04	VD	
Client Sample Description		12FD 1st Floor Ladies Room Left Sink Mixing Valve	Collected:		8/3/2021 8:23:00 AM	Lab ID:		012109114-0023
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.08	1.00 µg/L	8/26/2021	VD	08/27/21 4:10	VD	
Client Sample Description		13FD 1st Floor Ladies Room Middle Sink Mixing Valve	Collected:		8/3/2021 8:24:00 AM	Lab ID:		012109114-0025
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.54	1.00 µg/L	8/26/2021	VD	08/27/21 4:15	VD	
Client Sample Description		14FD 1st Floor Ladies Room Right Sink Mixing Valve	Collected:		8/3/2021 8:06:00 AM	Lab ID:		012109114-0027
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	2.36	1.00 µg/L	8/26/2021	VD	08/27/21 4:18	VD	
Client Sample Description		15FD 1st Floor Teacher's Lounge Sink Mixing Valve	Collected:		8/3/2021 8:29:00 AM	Lab ID:		012109114-0029
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	2.80	1.00 µg/L	8/26/2021	VD	08/27/21 4:21	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description		16FD 1st Floor Teachers Lounge Bottleless Water Fill	Collected:	8/3/2021 8:31:00 AM	Lab ID:	012109114-0031		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	8/26/2021	VD	08/27/21 4:24	VD	
Client Sample Description		17FD Nurses Bathroom Sink	Collected:	8/3/2021 8:36:00 AM	Lab ID:	012109114-0033		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.02	1.00 µg/L	8/26/2021	VD	08/27/21 9:38	VD	
Client Sample Description		18FD Bottleless Water Fill Next To Room 207	Collected:	8/3/2021 8:47:00 AM	Lab ID:	012109114-0035		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	8/26/2021	VD	08/27/21 9:41	VD	
Client Sample Description		19FD Water Fountain Bubbler Next to Room 207	Collected:	8/3/2021 8:50:00 AM	Lab ID:	012109114-0037		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.78	1.00 µg/L	8/26/2021	VD	08/27/21 9:44	VD	
Client Sample Description		20FD Room 207 Sink Mixing Valve	Collected:	8/3/2021 8:52:00 AM	Lab ID:	012109114-0039		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	1.01	1.00 µg/L	8/26/2021	VD	08/27/21 9:47	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114

CustomerID: OMEG50

CustomerPO: 21-26004

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700

Fax: (201) 489-8797

Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description		21FD Room 207 Bathroom Sink Mixing Valve	Collected:		8/3/2021 8:54:00 AM	Lab ID:		012109114-0041	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	2.59	1.00 µg/L		8/26/2021	VD	08/27/21 0:16	VD	
Client Sample Description		22FD Mens Bathroom Sink Across from Room 208 Mixing Valve	Collected:		8/3/2021 8:57:00 AM	Lab ID:		012109114-0043	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	ND	1.00 µg/L		8/26/2021	VD	08/27/21 0:24	VD	
Client Sample Description		23FD 2nd Floor Boys Bathroom Next to Room 201 Left Sink Mixing Valve	Collected:		8/3/2021 9:02:00 AM	Lab ID:		012109114-0045	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	2.94	1.00 µg/L		8/26/2021	VD	08/27/21 0:27	VD	
Client Sample Description		24FD 2nd Floor Boys Bathroom Next to Room 201 Middle Sink Mixing Valve	Collected:		8/3/2021 9:04:00 AM	Lab ID:		012109114-0047	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	2.00	1.00 µg/L		8/26/2021	VD	08/27/21 0:30	VD	
Client Sample Description		25FD 2nd Floor Boys Bathroom Next to Room 201 Right Sink Mixing Valve	Collected:		8/3/2021 9:05:00 AM	Lab ID:		012109114-0049	
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Lead	1.78	1.00 µg/L		8/26/2021	VD	08/27/21 0:33	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description 26FD Water Fountain Bubbler Next to Room 201 Right Sink		Collected: 8/3/2021 9:08:00 AM		Lab ID: 012109114-0051	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.82	1.00 µg/L	8/26/2021 VD	08/27/21 0:38 VD
Client Sample Description 27FD Bottleless Water Fill Next to Room 211		Collected: 8/3/2021 9:11:00 AM		Lab ID: 012109114-0053	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2021 VD	08/27/21 0:44 VD
Client Sample Description 28FD Water Fountain Bubbler Next to Room 203		Collected: 8/3/2021 9:16:00 AM		Lab ID: 012109114-0055	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.33	1.00 µg/L	8/26/2021 VD	08/27/21 0:46 VD
Client Sample Description 29FD Room 204 Sink		Collected: 8/3/2021 9:21:00 AM		Lab ID: 012109114-0057	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.64	1.00 µg/L	8/26/2021 VD	08/27/21 0:49 VD
Client Sample Description 30FD Water Fountain Bubbler Next to Room 204		Collected: 8/3/2021 9:26:00 AM		Lab ID: 012109114-0059	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.28	1.00 µg/L	8/26/2021 VD	08/27/21 0:58 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description		31FD 2nd Floor Girls Bathroom Next to Room 205 Left Sink Mixing Valve	Collected: 8/3/2021 9:33:00 AM		Lab ID: 012109114-0061	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS						
200.8	Lead	1.13	1.00 µg/L	8/26/2021	VD	08/26/21 23:33 VD
Client Sample Description		32FD 2nd Floor Girls Bathroom Next to Room 205 Middle Sink Mixing Valve	Collected: 8/3/2021 9:35:00 AM		Lab ID: 012109114-0063	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS						
200.8	Lead	ND	1.00 µg/L	8/26/2021	VD	08/26/21 23:38 VD
Client Sample Description		33FD 2nd Floor Girls Bathroom Next to Room 205 Right Sink Mixing Valve	Collected: 8/3/2021 9:37:00 AM		Lab ID: 012109114-0065	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS						
200.8	Lead	3.24	1.00 µg/L	8/26/2021	VD	08/26/21 23:41 VD
Client Sample Description		34FD Bottleless Water Fill in Music/Language Arts (Room 304)	Collected: 8/3/2021 9:46:00 AM		Lab ID: 012109114-0067	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS						
200.8	Lead	ND	1.00 µg/L	8/26/2021	VD	08/26/21 23:44 VD
Client Sample Description		35FD Room 304 Skills Kitchen Sink	Collected: 8/3/2021 9:48:00 AM		Lab ID: 012109114-0069	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst
METALS						
200.8	Lead	2.41	1.00 µg/L	8/26/2021	VD	08/26/21 23:50 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description 36FD Boys Bathroom Left Sink in Church Gym		Collected: 8/3/2021 10:01:00 AM		Lab ID: 012109114-0071	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	46.4	1.00 µg/L	8/26/2021 VD	08/26/21 23:52 VD
Client Sample Description 36FL Boys Bathroom Left Sink in Church Gym		Collected: 8/3/2021 10:02:00 AM		Lab ID: 012109114-0072	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	27.7	1.00 µg/L	8/27/2021 VD	08/27/21 20:39 VD
Client Sample Description 37FD Boys Bathroom Right Sink in Church Gym		Collected: 8/3/2021 10:03:00 AM		Lab ID: 012109114-0073	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	35.7	1.00 µg/L	8/26/2021 VD	08/26/21 23:56 VD
Client Sample Description 37FL Boys Bathroom Right Sink in Church Gym		Collected: 8/3/2021 10:04:00 AM		Lab ID: 012109114-0074	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	32.5	1.00 µg/L	8/26/2021 VD	08/26/21 23:58 VD
Client Sample Description 38FD Girl's Bathroom Left Sink in Church Gym		Collected: 8/3/2021 10:05:00 AM		Lab ID: 012109114-0075	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	8/26/2021 VD	08/26/21 23:59 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012109114
CustomerID: OMEG50
CustomerPO: 21-26004
ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

Client Sample Description 39FD Girl's Bathroom Right Sink in Church Gym		Collected: 8/3/2021 10:07:00 AM		Lab ID: 012109114-0077	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.9	1.00 µg/L	8/26/2021 VD	08/27/21 0:05 VD
Client Sample Description 40FD Unisex Bathroom in Church Gym		Collected: 8/3/2021 10:09:00 AM		Lab ID: 012109114-0079	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.84	1.00 µg/L	8/26/2021 VD	08/27/21 0:08 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 658-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com


EMSL Order:	012109114
CustomerID:	OMEG50
CustomerPO:	21-26004
ProjectID:	

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 08/10/21 9:00 AM

Project: Arch of Newark/St. Luke ECLC / 21-26004

Analytical Results

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - Indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

OrderID: 012109114

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

012109114

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: Cinnaminson.lead.lab@gmail.com

Customer Information Customer ID Company Name Omega Environmental Contact Name Street Address 280 Huyler Street City, State, Zip S. Hackensack, NJ 07606 Country USA Phone 201-489-8700 Email(s) for Report Lab@omega-env.com, sarahh@omega-env.com		Billing Information Billing ID Company Name Omega Environmental Billing Contact Street Address 280 Huyler Street City, State, Zip S. Hackensack, NJ 07606 Country USA Phone 201-489-8700 Email(s) for Invoice ap@omega-env.com	
Project Information Project Name/No. Arch of Newark/ St. Luke ECLC/ 21-26004 EMSL LIMS Project ID U.S. State where samples collected NJ State of Connecticut (CT) must select project location Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable) <input type="checkbox"/> Sampled By Name Ross Hernandez Sampled By Signature No. of Samples in Shipment 88			
Turn-Around-Time (TAT) <input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 32 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week			
Please call ahead for large projects and/or turnaround times 6 hours or less. *32 Hour TAT available for select tests only. Samples must be submitted by 11:30am.			
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT
CHIPS <input type="checkbox"/> by wt. <input type="checkbox"/> open imping. <input type="checkbox"/> imping.	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)
Reporting Limit based on a minimum 0.25g sample weight	SW 846-60100	ICP-OES	0.0004% (4ppm)
	NIOSH 7082	Flame Atomic Absorption	4µg/filter
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe
If no box is checked, non ASTM Wipe is assumed	SW 846-60100	ICP-OES	1.0µg/wipe
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1311 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW 846-1312 / SW 846-60100*	ICP-OES	0.1 mg/L (ppm)
TTLC	22 CCR App II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)
	22 CCR App II, SW 846-60100*	ICP-OES	2mg/kg (ppm)
STLC	22 CCR App II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
	22 CCR App II, SW 846-60100*	ICP-OES	0.1 mg/L (ppm)
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)
	SW 846-60100*	ICP-OES	2mg/kg (ppm)
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
Unpreserved			
Preserved with HNO3 <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)
Drinking Water	EPA 200.5	ICP-OES	0.003 mg/L (ppm)
Unpreserved			
Preserved with HNO3 <input checked="" type="checkbox"/> PH<2	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter
Other:			

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
Samples begin on the next page			

Method of Shipment		Sample Condition Upon Receipt	
Relinquished by Ross Hernandez	Date/Time 8/9/20 8:00	Received by OP 6020191218230m	Date/Time 8/10/20 9:00
Relinquished by	Date/Time	Received by	Date/Time

Controlled Document: CQC-25 Lead #16 4/19/2021

*6010C Available Upon Request



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 1 of 2

Page 1 of 7



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: (800) 220-3675
EMAIL: Cinnaminson.lab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABORATORIES - TRI-STATE

012109114

Only test Flush Sample if the corresponding First Draw Sample Result is 15ppb

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
01 FD	Room 101 Sink	250 mL	8/13/2021 7:54	Mixing Valve
01 FL	Room 101 Sink	250 mL	8/13/2021 7:55	Mixing Valve
02 FD	Water Fountain Bubble at 1st Floor Boys Bathroom	250 mL	8/13/2021 7:58	
02 FL	Water Fountain Bubble at 1st Floor Boys Bathroom	250 mL	8/13/2021 7:59	
03 FD	1st Floor Boys Bathroom Left Sink	250 mL	8/13/2021 8:00	Mixing Valve
03 FL	1st Floor Boys Bathroom Left Sink	250 mL	8:00	
04 FD	2nd Floor Boys Bathroom Middle Sink		8:01	
04 FL	1st Floor Boys Bathroom Middle Sink		8:02	
05 FD	1st Floor Boys Bathroom Right Sink		8:03	
05 FL	1st Floor Boys Bathroom Right Sink		8:03	
06 FD	Waterless Water Fill by Main Entrance	250 mL	8/13/2021 8:05	Filter Present
06 FL	Waterless Water Fill by Main Entrance	250 mL	8/13/2021 8:06	Filter Present
07 FD	Main Office Bathroom Sink		8:11	Mixing Valve
07 FL	Main Office Bathroom Sink		8:12	
08 FD	Principal's Office Bathroom Sink		8:13	
08 FL	Principal's Office Bathroom Sink		8:14	

Method of Shipment

Sample Condition Upon Receipt

Flushing performed by

Flushing performed by

Collected by

Collected by

Date / Time

Date / Time

Page 2 of 7

Order ID: 012109114



EMSL ANALYTICAL, INC.
TESTING • ANALYSIS • TREATMENT

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: (800) 220-3675
EMAIL: Cinnaminson@emsl.com

012109114

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
04 FD	Water Fountain Bubble next to Room 103	250 mL	8/13/2001 8:16	
04 FL	Water Fountain Bubble Next to Room 103	250 mL	8:17	
10 FD	Room 103 Sink		8:18	Mixing Valve
10 FL	Room 103 Sink		8:19	
11 FD	Water Fountain Bubble Next to Ladies Room		8:21	
11 FL	Water Fountain Bubble Next to Ladies Room		8:22	
12 FD	1st Floor Ladies Room Left Sink		8:23	Mixing Valve
12 FL	1st Floor Ladies Room Left Sink		8:23	
13 FD	1st Floor Ladies Room Middle Sink		8:24	
13 FL	1st Floor Ladies Room Middle Sink		8:25	
14 FD	1st Floor Ladies Room Right Sink		8:26	
14 FL	1st Floor Ladies Room Right Sink		8:27	
15 FD	1st Floor Teacher's Lounge Sink		8:29	
15 FL	1st Floor Teacher's Lounge Sink		8:30	
16 FD	1st Floor Teacher's Lounge Bottleless Water Fill		8:31	Filter Present
16 FL	1st Floor Teacher's Lounge Bottleless Water Fill		8:32	Filter Present

Method of Shipment:		Sample Condition Upon Receipt	
Received by:	Date/Time	Received by:	Date/Time
Received by:	Date/Time	Received by:	Date/Time

Order ID: 012109114



EMSL ANALYTICAL, INC.
FAST • ACCURATE • RELIABLE

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: (800) 220-3675
EMAIL: Cinnaminson@emsl.com

012109114

Only test Flush Sample if the corresponding First Draw Sample Result > 15ppb

Special Instructions and/or Regulatory Requirements (Sample Specifications, Preserving Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
17 FD	Nurse's Bathroom Sink	250 mL	8/13/08 8:36	
17 FL	Nurse's Bathroom Sink		8:37	
18 FD	Bottleless Water Fill Next to Room 207		8:47	Filter Present
18 FL	Bottleless Water Fill Next to Room 207		8:48	Filter Present
19 FD	Water Fountain Bubble Next to Room 207		8:50	
19 FL	Water Fountain Bubble Next to Room 207		8:51	
20 FD	Room 207 Sink		8:52	Mixing Valve
20 FL	Room 207 Sink		8:53	
21 FD	Room 207 Bathroom Sink		8:54	
21 FL	Room 207 Bathroom Sink		8:54	
22 FD	Men's Bathroom Sink Across from Room 208		8:57	
22 FL	Men's Bathroom Sink Across from Room 208		8:58	
23 FD	Boy's Bathroom Next to Room 201 Left Sink		8:59:08	
23 FL	Boy's Bathroom Next to Room 201 Left Sink		9:03	
24 FD	Boy's Bathroom Next to Room 201 Middle Sink		9:04	
24 FL	Boy's Bathroom Next to Room 201 Middle Sink		9:05	

Order ID: 012109114

Method of Shipment

Requisitioned by

Requisitioned by

Date/Time

Date/Time

Received by

Received by

Date/Time

Date/Time

Sample Condition Upon Receipt

Lead Chain of Custody

EMSL Order Number / Lab Use Only



EMSL ANALYTICAL, INC.
1441 N.W. 14th Avenue, Fort Lauderdale, FL 33304

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: (800) 220-3675
E-MAIL: Cinnaminson.nj@emsl.com

017109114

Special instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

*Only test Flush Sample if the corresponding First Draw Sample Result > 15ppb

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
25 FD	1st Boy's Bathroom Next to Room 201 Right Sink	250 mL	8/3/2001 9:05	Mixing Valve.
25 FL	1st Boy's Bathroom Next to Room 201 Right Sink		9:06	
26 FD	Water Fountain Bubble Next to Room 201		9:08	
26 FL	Water Fountain Bubble Next to Room 201		9:09	
27 FD	Bottleless Water Fill Next to Room 211		9:11	Filter Present
27 FL	Bottleless Water Fill Next to Room 211		9:12	Filter Present
28 FD	Water Fountain Bubble Next to Room 203		9:16	
28 FL	Water Fountain Bubble Next to Room 203		9:17	
29 FD	Room 204 Sink		9:21	
29 FL	Room 204 Sink		9:22	
30 FD	Water Fountain Bubble Next to Room 204		9:26	
30 FL	Water Fountain Bubble Next to Room 204		9:27	
31 FD	1st Floor Girls Bathroom Next to Room 205 Left Sink		9:33	Mixing Valve
31 FL	1st Floor Girls Bathroom Next to Room 205 Left Sink		9:34	
32 FD	1st Floor Girls Bathroom Next to Room 205 Middle Sink		9:35	
32 FL	1st Floor Girls Bathroom Next to Room 205 Middle Sink		9:36	

Order ID: 012109114

Method of Shipment	Sample Condition Upon Receipt
Received by	Received by
Date/Time	Date/Time

Lead Chain of Custody

EMSL Order Number / Lab Use Only



EMSL ANALYTICAL, INC.
P.O. BOX 1000 • PHILADELPHIA, PA 19106

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: (800) 220-3675
EMAIL: cinnaminson@emsl.com

01209114

*Only test Flush Sample if the corresponding First Draw Sample Result > 15ppb

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled	Notes
33 FD	2nd Floor Girls Bathroom Next to Room 205 Right Sink	250 mL	8/5/09	Mixing Valve
33 FL	2nd Floor Girls Bathroom Next to Room 205 Right Sink		9:38	Mixing Valve
34 FD	Right Bottleless Water Fill in Music/Karaoke Arts (Room 304)		9:46	Filter Present
34 FL	Bottleless Water Fill in Music/Karaoke Arts (Room 304)		9:47	Filter Present
35 FD	Room 304 Skills Kitchen Sink		9:48	
35 FL	Room 304 Skills Kitchen Sink		9:49	
36 FD	Church Boys Bathroom Left Sink in Church Gym		10:01	
36 FL	Boys Bathroom Left Sink in Church Gym		10:02	
37 FD	Boys Bathroom Right Sink in Church Gym		10:03	
37 FL	Boys Bathroom Right Sink in Church Gym		10:04	
38 FD	Girls Bathroom Left Sink in Church Gym		10:05	
38 FL	Girls Bathroom Left Sink in Church Gym		10:06	
39 FD	Girls Bathroom Right Sink in Church Gym		10:07	
39 FL	Girls Bathroom Right Sink in Church Gym		10:08	
40 FD	Unisex Bathroom in Church Gym		10:09	
40 FL	Unisex Bathroom in Church Gym		10:10	

Method of Sample:

Sample Condition Upon Receipt:

Received by: _____ Date / Time: _____

Received by: _____ Date / Time: _____

Order ID: 01209114



FMSL Order Number / Lab Use Only

EMAIL: Gunnar@cs.helsinki.fi or Gunnar@cs.helsinki.fi

Special Functions and Reg. Entry Requirements (Cosmetic Substitution, Final Offer, Merit, Levels of Importance, etc.)

Only test Flush Sample if the corresponding First Draw Sample Result $\geq 15\text{ppb}$

[illegible]

OrderID: 012109114